



4757 Canton Road, Suite #213 · Marietta, GA 30066 · (770) 425-0000

| | |
|-----------------------------------|----------------------------------|
| DATE 2/15/18 | CUSTOMER NAME SIMON WEINSTEIN |
| STREET ADDRESS 3730 MAYFAIR RD | |
| CITY BUCKHEAD | ZIP CODE 30342 |
| HOME TELEPHONE 404-791-5548 | |
| WK / CELL PHONE 404-239-9441 | TECHNICIAN LUDLEY |
| EMAIL: # 409 | |

SERVICE REQUEST:

| | | | |
|-----------------|-------------------------------------|---------------|--------------------------|
| SERVICE CALL | <input checked="" type="checkbox"/> | ESTIMATE | <input type="checkbox"/> |
| A/C INSPECTION | <input type="checkbox"/> | INSTALLATION | <input type="checkbox"/> |
| HEAT INSPECTION | <input type="checkbox"/> | CONTRACT HEAT | <input type="checkbox"/> |
| COMBO | <input type="checkbox"/> | CONTRACT A/C | <input type="checkbox"/> |

| SYSTEM #1 | | | | SYSTEM #2 | | | |
|------------------|------|------|-----|------------------|------|------|-----|
| AIR CONDITIONING | | | | AIR CONDITIONING | | | |
| | PASS | FAIL | N/A | | PASS | FAIL | N/A |
| ASSEMBLY | | | | ASSEMBLY | | | |
| REFRIGERANT | | | | REFRIGERANT | | | |
| LINE LEAKS | | | | LINE LEAKS | | | |
| DRAIN LINES | | | | DRAIN LINES | | | |
| TEMP. DROP | | | | TEMP. DROP | | | |
| INSTALLATION | | | | INSTALLATION | | | |
| THERMOSTAT | | | | THERMOSTAT | | | |
| WIRING | | | | WIRING | | | |
| CAPACITORS | | | | CAPACITORS | | | |
| COND COILS | | | | COND COILS | | | |
| CONTACTORS | | | | CONTACTORS | | | |
| COMPRESSOR | | | | COMPRESSOR | | | |
| STARTING | | | | STARTING | | | |
| COND. FAN | | | | COND. FAN | | | |
| DISCONNECT | | | | DISCONNECT | | | |
| BOOSTER | | | | BOOSTER | | | |
| FILTERS | | | | FILTERS | | | |
| AIR QUALITY | | | | AIR QUALITY | | | |
| HEATING EXAM | | | | HEATING EXAM | | | |
| | PASS | FAIL | N/A | | PASS | FAIL | N/A |
| PILOT | | | | PILOT | | | |
| HT EXCHANGER | | | | HT EXCHANGER | | | |
| AIR/GAS MIX | | | | AIR/GAS MIX | | | |
| FLAME | | | | FLAME | | | |
| FAN SPEED | | | | FAN SPEED | | | |
| BURNERS | | | | BURNERS | | | |
| BLOWER | | | | BLOWER | | | |
| SFTY CONTROLS | | | | SFTY CONTROLS | | | |
| VENT PIPE | | | | VENT PIPE | | | |
| TEMP. RISE | | | | TEMP. RISE | | | |
| THERMOSTAT | | | | THERMOSTAT | | | |
| AIRFLOW | | | | AIRFLOW | | | |
| COMBUST AIR | | | | COMBUST AIR | | | |
| BLOWER | | | | BLOWER | | | |
| F/L SWITCH | | | | F/L SWITCH | | | |
| PLENUM | | | | PLENUM | | | |
| GAS LEAKS | | | | GAS LEAKS | | | |
| IGNITION | | | | IGNITION | | | |
| GAS VALVE | | | | GAS VALVE | | | |
| VENT PIPE | | | | VENT PIPE | | | |
| CO PRESENT | | | | CO PRESENT | | | |
| INDUCER MTR | | | | INDUCER MTR | | | |
| FILTERS | | | | FILTERS | | | |
| AIR QUALITY | | | | AIR QUALITY | | | |
| ELEMENT STAGE | | | | ELEMENT STAGE | | | |
| DEFROST | | | | DEFROST | | | |

| OUR RECOMMENDATIONS ARE AS FOLLOWS: GA. REG. CN-208369 | CHARGE |
|--|-----------------|
| Upon Arrival have consultation w/ customer customer pay that heat quit working over the weekend. free diagnostic check and found nothing broke, not even the blower. As I continuing to do my diagnostic saw light on board, that indicate power is coming to the circuit board, recommend a troubleshooting since 1/2 hrs troubleshooting service @ \$85.00 | 29.95 |
| As I conclude my troubleshooting found that at this time the Blower Motor is not working recommend change, also remove very dirty filter from system. No FILTER IN SYSTEM Blower Motor @ 924.89 | Red Sheet Green |
| 1/2 Down - @ 500.00 | |

Your system is not operating correctly. Operation of your system "as is" may result in permanent damage and/or increased utility bills.

We have found carbon dioxide/gas leaks in your system. Operation of your system "as is" could be dangerous.

A Customer agrees to hold this Company harmless for the failure of the above outlined work. This Company does not believe that the customer is best served by performing the above work on the system; rather replacement is our strong recommendation.

SIGNATURE X *[Signature]*

1 I have authority to order the work outlined above. I have been informed of the additional charges for the work listed on this invoice. I agree to pay these additional charges upon receipt of this invoice. These additional charges do not cover unforeseen parts and labor which may be needed after the work begins. We are not always 100% positive that the work outlined above will remedy the problem or that this is the only problem with your system. Customer understands and agrees that if the work outlined above does not completely cure the problem, no refunds are allowed and additional costs will apply. Due to the nature of this type of work, unintended damage may occur. I understand and agree that this Company shall not be liable for incidental or consequential damages resulting from the performance of the work. Incidental and consequential damages include but are not limited to such things as: damage to ceilings, carpet, rugs, driveways, landscape, ladders, walls and furnishings. I agree to indemnify this Company from third party claims. Any permits or existing code violations will be at an additional expense to the customer. Customer understands the price listed here is a "flat rate" price for the work outlined above. This "flat rate" price includes the part cost (if any), plus labor and mark-up. Customer agrees that all sales are final and no refunds are allowed. Customer agrees that any and all disputes, disagreements and/or claims between the parties will be resolved through binding arbitration through Henning Mediation & Arbitration Service, Inc., or comparable service should Henning not be able to hear the matter, in accordance with their Rules and Procedures, as the same may be amended from time to time. This is the entire agreement. The parties are not bound by any oral expression, promise, commitment or representation that is not set forth on this invoice.

APPROVAL SIGNATURE X *[Signature]* Additional Charges \$ 29.95

2 LIMITED WARRANTY: By signing below, you agree: All materials, parts and equipment are warranted by the manufacturers' or suppliers' written warranty only. All labor performed by this Company is warranted for 30 days or as otherwise indicated in writing. No refunds are allowed. All Sales Final. There is no warranty on drain line leaks, refrigerant leaks, refrigerant services, refrigerant leak checks, drain cleaning services, water leaks, gas leaks, fan limit settings, pilot lighting services, service call recommendations, inspection recommendations, or replacement recommendations. You agree that we may telephone you, even if your number is found on a do not call registry or list. If refrigerant was added to system and refrigerant leaks out, we will have to return at an additional cost to find and repair leaks. Warranties provide coverage only to the customer listed on the agreement and are not transferable. Warranty work is performed: M - F 8AM to 4PM, excluding holidays. Warranty work is based on the availability of work crews. This Company shall not be liable for any damage caused by any delay in performing warranty work. All warranty work shall be performed by this Company's personnel only. Warranty is void if another entity or person or company works on system or warranted items during warranty period. Return Check Fee \$38.00. The work outlined above has been satisfactorily completed.

APPROVAL SIGNATURE X *[Signature]*

Grand Total \$ 500.00